



PFC Corofil Putty Pads



Application


PFC Corofil Putty Pads are designed to protect electrical switches and sockets with plastic or metal back boxes, that penetrate one or both faces of a plasterboard partition.

General benefits:

- Reduces noise transfer
- Pre-cut cross shape
- Low smoke emission
- Remains flexible
- · Available for single and double sockets

FIRE RATINGS

Tested to BS 476 Part 20:1987



Fire Rating

TECHNICAL INFORMATION

Available from our technical sales office.

Email tech@pfc-corofil.com for:

- Safety Data Sheet (SDAIPP)
- Installation Instructions (MSAIPP)





This data sheet shows the only applications the product has been tested in. Please ensure the product has been tested in, and is suitable for your application (see PFC Corofil terms and conditions 13.1.1).







PFC Corofil Putty Pads

Description

PFC Putty Pads are formed from a malleable sheet of silicone based putty containing an exfoliating intumescent material.

Fire rating when installed in one or both faces of a fire resistant plasterboard lined steel stud partition

Maximum integrity & insulation performance				
Integrity*	Insulation*			
120	120			

* The integrity and insulation rating will be dependent upon the partition being proven by test or assessment to provide the required fire rating performance in its own right.

Acoustic

Measurement of airborne sound insulation was made in accordance with BS EN ISO 140-3:1995. Single number quantities were calculated in accordance with BS EN ISO 717-1:1997. The Putty Pads provide a Weighted Sound Reduction Index (Rw) of up to 67dB.

Please order from our technical sales office.

PFC Corofil Units 3-4 King George Trading Estate Davis Road Chessington Surrey KT9 1TT

Tel: + 44 (0) 208 391 0533 Fax: + 44 (0) 208 391 2723 Email: sales@pfc-corofil.com

www.pfc-corofil.com





This data sheet shows the only applications the product has been tested in. Please ensure the product has been tested in, and is suitable for your application (see PFC Corofil terms and conditions 13.1.1).

Doc Reference			TDAIPP				
PB	SE	СВ	CI	AB			
This Copy			Review Date				
April 2018			April 2020				